

# *Middlefield Village Water Department Drinking Water Consumer Confidence Report 2025*

The Village of Middlefield has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included in this report is general health information, water quality test results, how to participate in decisions concerning your drinking water, how to help protect our drinking water and water system contacts. **Your drinking water met all Ohio EPA standards in 2025.**

## **What is the source of your drinking water?**

The Middlefield Village Water Department receives its water from three ground water wells. Wells #1 & #2 are located in the Tare Creek Watershed on state route 608 approximately 1.8 miles north of route 87. Well #3 is located on the Maple Highlands Trail between Tare Creek Parkway and Burton Windsor Road, just north of the covered bridge. The water is pumped from the wells to the filter treatment plant located on state route 608 approximately 0.5 miles north of route 87. Here the water is filtered and chlorinated then stored for contact time before being pumped into the distribution system and storage towers. Water consumption was down from 124.684 million gallons in 2024 to 115.928 million gallons in 2025, which is an average amount of water usage in comparison to the past several years.

Ohio EPA updated its source water assessment of the Middlefield Villages source of drinking water in 2025 to identify potential contaminant sources and provide guidance on protecting the drinking water source. This assessment indicates that Middlefield Village PWS's source of drinking water has a **high** susceptibility to contamination because; (1) The aquifer is located within a buried valley setting and is comprised of sand and gravel which is classified as a highly sensitive aquifer. (2) There is also the presence of significant potential contaminant sources in the protection area. (3) At This time there is no evidence to suggest that ground water has been impacted by any significant levels of chemical contaminants from human activities. This susceptibility means that under currently existing conditions, the likelihood of the aquifer becoming contaminated is high. This likelihood can be minimized by implementing appropriate protective measures and the risk of future contamination can be minimized by implementing appropriate protective measures.

The Middlefield Village updated its source water protection plan in 2025 and has implemented some precautionary measures, but protecting our drinking water source from contamination is the responsibility of all area residents. Should you need to find your Source Water Assessment Information, contact the Middlefield Village Municipal Center at 440-632-5248.

Please dispose of hazardous chemicals in the proper manner and report polluters to the appropriate authorities. Properly manage above ground storage tanks. Manage livestock, poultry, and horse waste. Manage agricultural fertilizer. Monitor gas wells for proper operation and notify the appropriate persons before drilling new wells. Comply with any and all hazardous material handling and transporting laws. These are some things that can help protect our drinking water.

Please take special caution to identify any items in your business or home containing mercury. If any items are found or broken exposing your home or business to mercury, use extra care to clean up and dispose of the items in the proper and approved manner. **Never** use a vacuum to clean up mercury. The vacuum will release mercury into the air and increase exposure. **Never** wash mercury down the drain. It may cause pollution of the wastewater treatment plant and the environment.

Items commonly containing mercury include fluorescent light bulbs, thermometers, thermostats, dry cell batteries and some switches. For a complete list of items containing mercury, how to dispose of them and clean up spills visit [www.epa.gov/hg/index.html](http://www.epa.gov/hg/index.html) .

Backflow prevention. What is it and why is it important? Backflow can be described as a reversal of the normal direction of flow within a piping system. Learn about the importance of backflow devices and backflow device

testing and how to submit your annual report at <http://www.middlefieldohio.com/village-services/water/> under the “Backflow” tab.

Only by working together can we ensure an adequate safe supply of water for future generations. More information about the source water assessment or what consumers can do to help protect the aquifer is available by calling the Village Hall. (440) 632-5248.

## **What are the sources of contamination in drinking water?**

Sources of drinking water both tap water and bottled water, includes rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive materials, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas productions, mining or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water run-off, and septic systems; (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limits the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (1-800-426-4791).

## **Who needs to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

## **About your drinking water.**

The EPA requires regular sampling to ensure drinking water safety. In addition to operational sampling and testing, the Middlefield Water Department conducted sampling for bacteriological, residual disinfectants, residual disinfectant byproducts, lead, copper, nitrate and arsenic. Samples were collected for a total of 15 different contaminants in 2025. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

## **How to read the Water Quality Data Table.**

EPA establishes the safe drinking water regulations that limits the amount of contaminants allowed in drinking water. The water quality section summarizes the concentrations of detected substances in comparison to regulatory limits. Substances that were tested for, but not detected, are not included in this table. In 2025, we had an unconditioned license to operate our water system.

## Water Quality Section

Inorganic Chemicals							
<u>CONTAMINANTS</u>	<u>MCLG</u>	<u>MCL</u>	<u>Level Found</u>	<u>Range of Detection</u>	<u>VIOLATIONS</u>	<u>Year Sampled</u>	<u>Typical Source of Contaminant</u>
Arsenic (ppb)	0	10	2	<2 - 3	No Violations	2024 - 2025	Erosion of natural deposits; Runoff from orchards, glass and electronics production wastes.
Fluoride (ppm)	4	4	0.24	NA	No Violations	2023	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
Barium (ppm)	2	2	0.07	NA	No Violations	2023	Erosion of natural deposits; Water additive which promotes strong teeth; discharge from aluminum and fertilizer factories.
Nitrate (ppm)	10	10	0.11	NA	No Violations	2025	Run off from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

Residual Disinfectants							
<u>CONTAMINANTS</u>	<u>MCLG</u>	<u>MCL</u>	<u>Level Found</u>	<u>Range of Detection</u>	<u>VIOLATIONS</u>	<u>Year Sampled</u>	<u>Typical Source of Contaminant</u>
Total Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.13	.9 – 1.2	No Violations	2024 - 2025	Water additives to control microbes

Disinfection Byproducts							
TTHM's (Total Trihalomethanes)							
<u>CONTAMINANTS</u>	<u>MCLG</u>	<u>MCL</u>	<u>Level Found</u>	<u>Range of Detection</u>	<u>VIOLATIONS</u>	<u>Year Sampled</u>	<u>Typical Source of Contaminant</u>
Total THM's (ppb)	N/A	80	48.1	28.9 – 48.1	No Violations	2025	By –Product of drinking water chlorination
HAA5 (Haloacetic Acids)							
Total HAA5's (ppb)	N/A	60	25.1	13.2 – 25.1	No Violations	2025	By –Product of drinking water chlorination

Unregulated Disinfection Byproducts							
<u>Contaminant</u>	<u>Average</u>	<u>Range</u>			<u>Violations</u>	<u>Year Sampled</u>	
Chloroform (ppb)	20.2	12.9 – 27.5			NA	2025	By –Product of drinking water chlorination
Bromoform (ppb)	0.649	.558 - .74			NA	2025	By –Product of drinking water chlorination
Bromodichloromethane (ppb)	11.455	9.31 – 13.6			NA	2025	By –Product of drinking water chlorination
Dibromoacetic Acid (ppb)	1.6	1.56 – 1.64			NA	2025	By –Product of drinking water chlorination
Dichloroacetic Acid (ppb)	10.685	7.77 – 13.6			NA	2025	By –Product of drinking water chlorination
Trichloroacetic Acid (ppb)	6.855	3.88 – 9.83			NA	2025	By –Product of drinking water chlorination

## Water Quality Section

Lead and Copper							
Contaminants (Units)	Action Level (AL)	Individual Results over the AL	90% of test levels were less than	Number of samples greater than the AL	Violations	Year Sampled	Typical source of Contaminants
Lead (ppb)	15 (ppb)	NA	<5	0 of 10	No Violations	2025	Corrosion of household plumbing systems
Zero of 10 lead samples were found to have levels in excess of the lead action level of 15ppb.							
Copper (ppm)	1.3 (ppm)	NA	0.43	0 of 10	No Violations	2025	Corrosion of household plumbing systems
Zero of 10 copper samples were found to have levels in excess of the copper action level of 1.3 ppm.							

Additional Water Quality Information & Operating Data						
Sample	Average	Measured in	Range of Detection	Violations	Year Sampled	Reason for Sample
PH	7.6	0 (acidic) – 14 (alkaline)	7.5 – 7.8	No Violations	2025	Monitoring of water condition as an acidic or alkaline state. Effects pipe conditions and water quality.
Total Alkalinity (ppm)	217	CaCO3	194 - 240	No Violations	2025	Indicates resistance to PH change and buffering capacity of the water to neutralize acid. Also effects taste.
Total Hardness (ppm)	251	CaCO3	240 -275	No Violations	2025	Related to Alkalinity. Indicator of dissolved minerals in water. Helpful info for home owners and businesses.
Total Hardness (gpg)	14.7	CaCO3	14.0 – 16.1	No Violations	2025	Related to Alkalinity. Indicator of dissolved minerals in water. Helpful info for home owners and businesses.
Total Iron (ppm)	0.01	Fe	.01 - .02	No Violations	2025	Indicator of the effectiveness of Arsenic removal system. Removal of iron also improves taste and appearance of water.
Total Manganese (ppm)	0.01	Mn	.01 - .01	No Violations	2025	Indicator of the effectiveness of the Arsenic removal system. Removal of Manganese also improves taste and appearance of water.
Total Phosphorous (ppm)	1.01	P	.75 – 1.08	No Violations	2025	Monitoring of sodium phosphate blend addition for iron sequestering and pipe conditioning.

## Lead Educational Information:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Middlefield Village water system is responsible for providing high quality water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline at 800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Per the Lead and Copper Rules, Public Water Systems were required to develop and maintain a Service Line Inventory. A service line is the underground pipe that supplies your home or building with water. To view the Service Line Inventory, which lists the material type(s) for your location, it is accessible at Middlefield Village Hall, 14860 North State Avenue, Middlefield, Ohio 44062 between the hours of 8am and 4pm Monday-Friday (excluding any holidays the office is closed).

Our distribution system has no lead, galvanized requiring replacement, or lead status unknown service lines. To determine this, we used the following sources. Visual inspection and Resident Self Reporting.

## How do I participate in the decisions concerning my drinking water?

Public participation and comment are encouraged at regular meetings of the Middlefield Village Council which meets the second Thursday of every month at 7:00 p.m. For more information on your drinking water, contact Michael Cipolla, Water Plant Manager, Joseph Tucholski, Director of Streets and Utilities, or Leslie Gambosi, Village Administrator at 440-632-5248.

## Definitions of some terms contained in this report.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Residual Detection Level Goal (MRDLG):** The level of residual disinfectant below which there is no known or expected risk to health.

**Maximum Residual Detection Level (MRDL):** The highest residual disinfectant level allowed.

**Parts per Million (ppm) or Milligrams per Liter (mg/L):** Are units of measure of concentration of a contaminant. A part per million corresponds to one second in approximately 11.5 days.

**Parts per Billion (ppb) or Micrograms per Liter (ug/L):** Are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years

**PFAS:** Per – and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals applied to many industrial, commercial and consumer products to make them waterproof, stain resistant, or nonstick. PFAS are also used in products like cosmetics, fast food packaging, and a type of firefighting foam called aqueous film forming foam (AFFF) which are used mainly on large spills of flammable liquids, such as jet fuel. PFAS are classified as contaminants of emerging concern, meaning that research into the harm they may cause to human health is still ongoing.

**Grains per Gallon (gpg):** A unit of water hardness defined as 1 grain of calcium carbonate (CaCO<sub>3</sub>) dissolved in 1 US gallon of water.

**The “<” symbol:** A symbol which means less than. A result of < 5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.

**Action Level (AL):** The concentration of contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**NA:** Not Applicable. A code used in drinking water reporting for a particular category that does not apply to the results.